

Tender Questions & Answers

FROM:	DANISH REFUGEE COUNCIL
Tender No:	ITB-001TIK22
Tender Title:	TB-001TIK22 - Rehabilitation and maintenance
Tender Issuing Date:	05-06-2022
Tender Closing Date:	25-06-2022

Danish Refugee Council Iraq has in reference to above tender period received the following questions to the Tender, and hereby provides responsive answers by best endeavour to all relevant Vendors & Suppliers.

#	Enquiries to the Tender		
	Date	Question	Answer
1	15-06-2022	<p>When searching for submersible pumps (Ideal brand) in the local market, we could not find a submersible pump with a capacity of 200 m³/h and and head of 30 meters, instead, we found pumps with a head of 25 meters, can we supply pumps with a head of 25 meters?</p> <p>عند البحث لدى وكلاء مضخات ايدىال في السوق المحلية لم نستطع ايجاد مضخة غاطسة سعة 200 متر مكعب \ ساعة و هيد (30 متر) و لكننا وجدنا مضخات ذات هيد 25 متر ، هل يمكننا تجهيز مضخات ذات هيد 25 متر؟</p>	<p>This point was discussed with the Salah al-Din Water Directorate and they informed DRC that it is possible to supply IDEAL pumps with a head of 25 meters, provided that their capacity is 230 cubic meters/hour instead of 200.</p> <p>تمت مناقشة هذه النقطة مع مديرية ماء صلاح الدين و ابلغونا انه بالامكان تجهيز مضخات ايدىال ذات هيد 25 متر بشرط ان تكون سعتها 230 متر مكعب \ ساعة بدلا من 200.</p>

On behalf of DRC

Yours sincerely,



22-06-2022

